

Some updates on the Cherenkov Detector

Zhonghua Qin


CEPC Day, March 2, 2026

Detector material budget estimation


- Total material budget: ~2.83%

Materials	Thickness	Radiation Length(X0)	Material Budget (T/X0)
Aerogel	6cm	731cm	0.82%
SiPM	1mm	9.36cm	1.06%
PCB(FR-4)	1mm	19.4cm	0.51%
PCB(copper)	30 μ m	1.43cm	0.21%
Carbon Fiber	0.4mm	40cm	0.10%
Air	40cm	304 m	0.13%
Total			2.83%

Some parts are still missing: cables, electronics, cooling etc.




Wall (carbon fiber)



Impact on momentum resolution


- A preliminary simulation result (ITK+TPC+OTK) : $\sim 0.15\%$ degradation at $\theta=15^\circ$ ($\cos \theta=0.97$) for low Pt region (1 to 10 GeV/c)
- Current setup: Cherenkov detector between 3rd and 4th endcap ITK. Will test the other position

From
Changru Li



$$\theta_0 = \frac{13.6 \text{ MeV}}{\beta c p} \cdot z \cdot \sqrt{\frac{x}{X_0}} \left[1 + 0.038 \ln \left(\frac{x}{X_0} \right) \right]$$

$$\approx \begin{cases} 2.1 \text{ mrad}, p = 1 \text{ GeV} \\ 0.1 \text{ mrad}, p = 20 \text{ GeV} \end{cases}$$



Coverage: $9.3^\circ < \theta < 28.8^\circ$
 or $0.88 < \cos \theta < 0.99$

Consideration on SiPM dark noise

- Estimation of **false hits from dark noise** in the photon detector plane :

$$\begin{aligned} N_{\text{false hits}} &= \text{Dark noise rate} \times \text{Readout time window} \times \text{Photon detector area} \\ &= 200 \times 10^3 \times 69 \times 10^{-9} \times 0.8 \times 10^6 \\ &= \mathbf{10000} \end{aligned}$$



Typical dark noise rate: 200 kHz/mm²

Readout time window: 69 ns(same as VTX, ITK, OTK, Ecal, Muon)

Photon detector area: 0.8 m²

- With tracking information incorporated:
 - Momentum: Ring diameter (Max. ~ 8 cm),
 - Track: Intersection point (ring center)
 - **false hits can be reduced by a factor of ~100**
 - **relaxes the requirement for SiPM dark noise rate**

However, beam background and secondary particles are not included in this estimate.




Consideration on SiPM spatial resolution

- To achieve 3σ K/ π separation at 20 GeV/c, a good Cherenkov angle resolution ($\sigma(\theta_c(tot))$) of **0.7 mrad** is needed;
- Resolve the spatial resolution from the Cherenkov angle resolution formula:

$$\begin{aligned} \sigma(\theta_c(tot)) &= \frac{\sigma(\theta_c(1pe))}{\sqrt{Npe}} \\ &= \frac{1}{\sqrt{Npe}} \left(\sqrt{\sigma_{spatial}^2 + \sigma_{thick}^2 + \sigma_{track}^2 + \sigma_{chromatic}^2} \right) \\ &= \frac{1}{\sqrt{Npe}} \left(\sqrt{\left(\frac{\Delta_{size}}{L\sqrt{12}}\right)^2 + \left(\frac{t \sin \theta_c}{L\sqrt{12}}\right)^2 + \sigma_{track}^2 + \left(\frac{\Delta_n}{n \tan \theta_c}\right)^2} \right) \end{aligned}$$

Assume $\Delta_{size} = 1mm$, $t = 20mm$, $\sigma_{track} = 0.5mm$, $\Delta_n = 0.0001$ ($n = 1.008$), $Npe = 15$,
Then $\sigma(\theta_c(tot)) \approx 0.7 \text{ mrad}$

Currently under checking the chromatic dispersion of aerogel in 300-700 nm wavelength range



A SiPM of 1mm x 1mm, or $\sigma_{spatial} = 280 \mu m$ is desirable

Preliminary requirements for SiPM

Discussed with Yong Liu, Zhijun etc..

Parameters	preliminary requirement
Wavelength	300 nm – 700 nm
Photon detection efficiency	>50% at 420nm
SiPM active area (two types)	1 mm x 1 mm (conventional) 3 mm x 3 mm (position sensitive)
Dark noise rate	< ~10 kHz/mm ² (to be further studied)
Spatial resolution	~280 μm
Radiation tolerance	~10 ¹³ N _{eq.} /cm ² (to be further studied)

Additional parameters such as pixel pitch, cross talk, etc. need to added later

PS: for radiation hardness:

-NIEL in forward region: ~1x10¹¹ Neq. /cm² /year

-So the requirement for SiPM: 1x10¹² Neq./cm², or 1x10¹³ Neq./cm² more conservatively

Detector R&D goals with IHEP innovation fund

In 2-3 years:

- Complete the detector conceptual design report (CDR)
 - including radiator, photodetector, mechanics, preliminary simulation, detector performance studies
 - CDR will be reviewed by international experts (put on arXiv or published)
- Construct a detector prototype
 - A small-scale of prototype is currently planned: an aerogel block ($\sim 10 \times 10 \text{ cm}^2$ or $20 \times 20 \text{ cm}^2$) + a SiPM module ($\sim 20 \times 20 \text{ cm}^2$)
 - Will see if a larger prototype is needed later
- Perform cosmic-ray tests/beam tests
 - Cosmic-ray tests are convenient but cannot provide quantitative detector parameters
 - Beam tests are beneficial but require an appropriate test facility

In addition:

- A general NSFC program is currently under application, also plan to apply for an NSFC-RSF joint fund.

Summary and outlook

- A preliminary material budget of $\sim 2.83\%$ is estimated (partial components to be supplemented); first simulation on momentum resolution shows $\sim 0.15\%$ degradation at low p_T , with test the other position
- Dark noise-induced false hits can be reduced by $\sim 100x$ with tracking info, but need to consider other sources of false hits (beam background, secondaries)
- Requirements for some SiPM parameters are defined, while other parameters require further studies
- R&D goals are set under the IHEP fund, some refinements need more considerations