

Several Significant Fault Recoveries and the Operation Status of the PLS-II

Thursday, 14 November 2019 09:30 (30 minutes)

PLS-II has been upgraded from PLS (Pohang Light Source) from 2011. There are two important changes. At first electron beam energy changed from 2.5 GeV to 3.0 GeV. The other is operation mode from decay to top-up. For them, RF systems in the storage ring were changed from 5 normal conducting cavities to 3 super conducting cavities. And the super conducting system is the largest fault source in operation by several big issues related in cryogenic systems. On the 15th of November, an earthquake occurred 9 km away from the facility with a magnitude 5.4. It also took 21 days to recover all of the systems related in the electric power problem. And another big problem was the overheating of the magnets. Including these problems, this report will describe the operation status of the PLS-II with various operational parameters

Primary author: Ms KIM, Mungyung (PAL)

Co-authors: Dr HWANG, Ilmmon (PAL); Dr SHIN, Seunghwan (PAL); Dr HA, Taekyun (PAL); Dr JOO, Young-Do (PAL)

Presenter: Ms KIM, Mungyung (PAL)

Session Classification: Safety Culture, Human Factors and Managerial Decisions