


Update on the sensor test etc.

03/07/2019

IV measurement settings


- Measurements done with all pads and the guard ring (GR) connected.
 - 24 neighbor pads and GR are connected to ground.
 - Keithley 2410 provides HV applied to the back of the sensor.
 - Keithley 2400 measures the pad current.
 - Current compliance and limit: $1\mu\text{A}$
 - Filter enabled.

Much improved resolution with the new settings →




HPK 5x5 sensors : comparison with and w/o UBM


Type 3.1




Type 3.2



Reference : Figure 5.4, TDR (pre. ver.)



(a) I-V for different runs.



(c) I-V for different types and conditions.

Our result looks similar to those. (Type3.2 UBM is not shown)

Order of 10^{-12} (pA) would be needed for Type3.1 to see structures



Array test table : (final call just before this meeting ...)

Type 3.1							Type 3.2						
Sensor	Sensors tested	Pads tested	Number of Perfect Sensors	Number of Good Pads	Fraction of Perfect Sensors [%]	Fraction of Good Pads [%]	Sensor	Sensors tested	Pads tested	Number of Perfect Sensors	Number of Good Pads	Fraction of Perfect Sensors [%]	Fraction of Good Pads [%]
Single (based on HPK probing)	648	648	648	648	100	100	Single (based on HPK probing)	216	216	216	216	100	100
Single SE5	360	360	360	360	100	100	Single SE5	120	120	120	120	100	100
Single SE5	144	144	144	144	100	100	Single SE5	48	48	48	48	100	100
Single SE5	144	144	144	144	100	100	Single SE5	48	48	48	48	100	100
5x5 All groups	17	425	17	425	100	100	5x5 All groups	5	125	5	125	100	100
15x15 All groups	8	1800	7	1799	87.5	99.94444444	15x15 All groups	3	675	2	673	66.66666667	99.7037037
Göttingen:							Göttingen:						
5x5	6	150	6	150	100	100	5x5	1	25	1	25	100	100
15x15	7	1575	6	1574	85.71428571	99.93650794	15x15	3	675	2	673	66.66666667	99.7037037
UCSC:							UCSC:						
5x5	10	250	10	250	100	100	5x5	2	50	2	50	100	100
15x15	1	225	1	225	0	1	15x15	0	0				
IHEP:							IHEP:						
5x5	1	25	1	25	100	100	5x5	2	50	2	50	100	100
15x15							15x15						
BNL:							BNL:						
5x5							5x5						
15x15							15x15						
JSI:							JSI:						
5x5							5x5						
15x15							15x15						

+ 2 Type3.1 sensors (Wo.1/Wo.2)

+ 1 Type3.2 sensors (Wo.17)

Test of the MUX evaluation board



Power Supply (P.S.) : Now with batteries (+12V)

Test of the MUX evaluation board

- Current fluctuation was $O(10)\mu\text{A}$ (including precision of SMU itself)

➔ As expected from spec. sheet

- Address is controlled with shunts, therefore, the current fluctuation by using digital level from Raspberry Pi is the next issue. (personally, expecting the necessity of isolators)



Fig : $1\text{V}/1\text{M}\Omega = 0.01\ \mu\text{A}$ with fluctuation

Technical document on MUX36xxx (Texas Inst.)

		$T_A = -40^\circ\text{C to } +125^\circ\text{C}$				58	
	On-resistance drift	$V_S = 0\ \text{V}$		0.62		$\Omega/^\circ\text{C}$	
$I_{S(OFF)}$	Input leakage current	Switch state is off, $V_S = \pm 10\ \text{V}, V_D = \pm 10\ \text{V}^{(1)}$	$T_A = -40^\circ\text{C to } +85^\circ\text{C}$	-0.04	<u>0.001</u>	0.04	nA
			$T_A = -40^\circ\text{C to } +125^\circ\text{C}$	-0.15		0.15	
				-1.2		1.2	
	Output off leakage	Switch state is off,		-0.15	0.01	0.15	

Next

(from my side)

- Setup Raspberry PI
- IV on 5x5 arrays with KEITHLEY 6487
(depending on the schedule)